



® TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.

Technical and Test Institute for Construction Prague

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán, Inspekční orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body, Inspection Body  
Prosecká 811/76a, 190 00 Praha 9, Czech Republic

Branch 0300 – Pilsen

# CERTIFICATE

č. 030 – 044035

## about the qualities of a product

**Certified quality:** Slipperiness according to the following test procedures:

**DIN 51130** Testing of floor coverings – Determination of the anti – slip properties – Workrooms and fields of activities with slip danger, walking method – Ramp test

**Product:** Floor coverings Thermofix

**Producer:** Fatra, a. s.

tř. T. Bati č. p. 1541, 763 61 Napajedla, Czech Republic

**Order:** Z 030100383

**Achieved values:**

DIN 51130	
18,1°	group R10

The certificate is issued on the basis of the results of the tests stated in report no. 030\_044019.

Number of pages of certificate: 1

Certificate validity: **2012 December 31**

The certificate can be cancelled upon fading non-adherence to the certified parameters of product qualities.

Pilsen 2010 December 17



**Ing. Alexander Trinner**  
director of branch

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300-Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic

☎: 377 243 331, ☎: 377 430 345, Fax: +420 377 430 347, Internat.: +420 377 244 158,  
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100

✉ e-mail: atrinner@tzus.cz, www.tzus.cz  
Co.Id.No.: 000 15679 Tax Co. Id. No.: CZ00015679